



ROOM NO.	ROOM NAME	ROOM NO.	ROOM NAME
2001	OPEN OFFICE	2321	CORRIDOR
2002	OFFICE	2502	OFFICE
2003	OFFICE	2503	OFFICE
2004	DEPARTMENT HEAD	2504	OFFICE
2005	OFFICE	2505	OFFICE
2006	OFFICE	2506	OFFICE
2007	OFFICE	2507	OFFICE
2008	OFFICE	2508	OFFICE
2009	OPEN OFFICE	2509	OPEN OFFICE
2010	OFFICE	2510	OFFICE
2011	OFFICE	2511	OFFICE
2012	OFFICE	2512	OFFICE
2013	OFFICE	2513	OFFICE
2014	OFFICE	2514	OFFICE
2015	OFFICE	2515	OFFICE
2020	CORRIDOR	2520	CORRIDOR
2021	CORRIDOR	2701	OPEN OFFICE
2022	CORRIDOR	C-21	COMM.
2301	LOBBY	E-22	ELECTRICAL
2304	OFFICE	J-21	JANITOR
2305	OFFICE	PS-21	CORRIDOR
2306	OFFICE	PS-22	LOBBY
2307	OFFICE	PS-23	ELEVATOR LOBBY
2308	OFFICE	PS-24	ELEVATOR LOBBY
2309	OPEN OFFICE	S1-2	STAIR #1
2310	OFFICE	S2-2	STAIR #2
2311	OFFICE	S3-2	STAIR #3
2312	OFFICE	S4-2	STAIR #4
2313	OFFICE	TW-21	MEN
2314	OFFICE	TW-22	WOMEN
2320	CORRIDOR		

- 8 - 1 - cat6
- 1 - 3 - cat6
- 10 - 6 - cat6
- 1 - 1 - cat6, 1- 18/4 stranded

POWER PLAN - SECOND FLOOR

Scale: 1/8" = 1'-0"

KEYED NOTES:

- POWER FOR FIRE CURTAIN. PROVIDE A FIRE ALARM CONNECTION.
- MOUNT RECEPTACLE BELOW THE COUNTER AND NEAR THE LEADING EDGE.
- RECEPTACLE FOR AUTOMATIC FAUCET AND SOAP DISPENSER. MOUNT THE RECEPTACLE BELOW THE COUNTER. ELECTRICAL CONTRACTOR SHALL MAKE ALL FINAL CONNECTIONS.
- POWER CONNECTIONS FOR ELECTRIC HAND DRYERS. VERIFY MOUNTING HEIGHT WITH ARCHITECT PRIOR TO ROUGH IN.

GENERAL NOTES:

- SEE ARCHITECTURAL DRAWINGS FOR EXACT OUTLET LOCATIONS.
- ROUTE ALL CONDUITS ABOVE ACCESSIBLE CEILINGS TO THE EXTENT PRACTICAL. CONDUITS ROUTED DOWN MAIN CORRIDORS SHALL BE RUN AT 90° ACROSS THE CORRIDORS.